

INDIRA GANDHI NATIONAL OPEN UNIVERSITY
REGIONAL CENTRE: SAHARSA
 Naya Bazaar, Saharsa-852201 (Bihar)
 Ph.: 06478-219015, Email: rcsaharsa@ignou.ac.in,
 Website: www.ignourcsaharsa.ac.in & www.ignou.ac.in

F.No. IG/RC-86/Procurement/14/_____

Dated: _____

CORRIGENDUM

Subject: Extension in submission of tender date.

- Ref: 1. Tender Notice No. F.No. IG/RC-86/Procurement/Furniture/14/ 768 Dated 10th September, 2014
 2. Tender Notice No. F.No.IG/RC-86/Procurement/DG Set/14/806 Dated 19th September, 2014
 3. IG/RC-86/Procurement/Lipi Printer/14/805 Dated 19th September, 2014

The last date of issuance and submission of above referred tenders has been extended and rescheduled as under:

| S.No. | Tender of Articles | Revised Last Date & time for issue of tender Paper | Revised Date & time of Opening of tender |
|-------|-------------------------------------------------|----------------------------------------------------|------------------------------------------|
| 01. | Tender for purchase of furniture | 03.11.2014 (02:00 PM) | 03.11.2014 (03:30 PM) |
| 02. | Tender for purchase of Silent DG Set | 03.11.2014 (02:00 PM) | 03.11.2014 (03:30 PM) |
| 03. | Tender for purchase of Lipi Line Matrix Printer | 03.11.2014 (02:00 PM) | 03.11.2014 (03:30 PM) |

All other terms & conditions of the above referred tenders shall remain unchanged except Silent DG Set specifications. Silent DG Set specifications modified as under:

TECHNICAL SPECIFICATIONS OF OF NOISELESS AUTO DIESEL GENERATOR SET 10 KVA

| S.No | Parameter | Specification |
|------|----------------------------------|-------------------------------------------------------------------------------------------------------------------------------|
| 1 | Rating | 10KVA(+ 10% upwards variations) |
| 2 | Excitation | Self excited and self regulated |
| 3 | Speed | 1500 RPM |
| 4 | Cooling System* | Water Cooled/Air Cooled* |
| 5 | Start | Electric Start |
| 6 | Speed / Frequency | 1500 RPM/50Hz |
| 7 | Environment protection | The DG set must meet all environment protection rules & regulations of Govt. of India in respect of noise and emission norms. |
| 8 | Standards | Alternator and Generator and other items used in the DG set should conform to ISI standards. |
| 9 | Installation | Vendor must quote for installation, Earthing and commissioning of the DG set at the site. |
| 10 | Warranty | All inclusive warranty of 24 months. |
| 11 | Documents | All manuals for operation and maintenance of the DG set must be provided. |
| 12 | Output Voltage Variation on load | 220 Volt $\pm 5\%$ |
| 13 | Output Frequency on load | 50 Hz $\pm 0.25\%$ |
| 14 | Comprehensive Warranty | Two Year at site |

(Dr. S. S. Singh)
Regional Director